

# **Solar Desalination System Design for Irrigation/Drinking Water and Electricity Generation in Desert or Arid Areas**


**Jose Izquierdo, Richard E. Blanchard \***

Loughborough University, Loughborough LE11 3TU, UK

\* Correspondence: Richard E. Blanchard; Email: r.e.blanchard@lboro.ac.uk.

## **SUPPLIMENTARY DATA FILE**

## APPENDIX A: MAP WITH LOCATION OF THE PROJECT




From <http://www.un.org/Depts/Cartographic/map/profile/wsahara.pdf>

Coordinates: 26.172147, -11.0875829

## APPENDIX B: SURFACE METEROLOGY AND SOLAR ENERGY DATA FROM NASA (ATMOSPHERIC SCIENCE DATA CENTER)

5/28/2017

NASA Surface meteorology and Solar Energy - Available Tables



### Geometry Information

Elevation: 306 meters  
taken from the  
NASA GEOS-4  
model elevation

Northern boundary	Center	Eastern boundary
27	Latitude 26.5 Longitude -11.5	-11
Western boundary		Eastern boundary
-12		
Southern boundary		
26		

### *Parameters for Sizing and Pointing of Solar Panels and for Solar Thermal Applications:*

#### Monthly Averaged Insolation Incident On A Horizontal Surface (kWh/m<sup>2</sup>/day)

Lat 26.172 Lon -11.088	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Annual Average
22-year Average	3.81	4.68	5.89	6.98	7.39	7.56	7.35	6.80	5.87	4.83	3.95	3.38	5.71

#### Minimum And Maximum Difference From Monthly Averaged Insolation (%)

Lat 26.172 Lon -11.088	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Minimum	-9	-14	-7	-6	-6	-7	-8	-5	-8	-11	-9	-15
Maximum	7	10	6	4	6	7	7	10	6	9	13	15

#### Parameter Definition

#### Monthly Averaged Diffuse Radiation Incident On A Horizontal Surface (kWh/m<sup>2</sup>/day)

Lat 26.172 Lon -11.088	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Annual Average
22-year Average	1.09	1.28	1.48	1.65	1.86	1.93	1.93	1.83	1.68	1.43	1.16	1.07	1.53
Minimum	0.99	1.07	1.32	1.51	1.66	1.69	1.71	1.54	1.54	1.26	0.96	0.89	1.35
Maximum	1.19	1.48	1.63	1.83	2.04	2.14	2.14	1.97	1.83	1.58	1.26	1.18	1.69
22-year Average K	0.58	0.60	0.63	0.66	0.66	0.66	0.65	0.64	0.61	0.59	0.57	0.55	0.62

[https://eosweb.larc.nasa.gov/cgi-bin/sse/grid.cgi?num=169117&lat=26.172&submit=Submit&gt;=100&veg=17&sitelev=&email=skip@larc.nasa.gov&grid\\_id&p=swdwncook&p=midday\\_dwn&p=clrskycook&p=clrskyday&p...](https://eosweb.larc.nasa.gov/cgi-bin/sse/grid.cgi?num=169117&lat=26.172&submit=Submit&gt;=100&veg=17&sitelev=&email=skip@larc.nasa.gov&grid_id&p=swdwncook&p=midday_dwn&p=clrskycook&p=clrskyday&p...)

5/28/2017

NASA Surface meteorology and Solar Energy - Available Tables

Minimum K	0.53	0.51	0.59	0.62	0.62	0.61	0.60	0.60	0.56	0.52	0.52	0.47	0.56
Maximum K	0.62	0.66	0.67	0.69	0.70	0.71	0.70	0.70	0.64	0.64	0.65	0.63	0.67

**NOTE:** Diffuse radiation, direct normal radiation and tilted surface radiation are not calculated when the clearness index (K) is below 0.3 or above 0.8.

#### Parameter Definition

#### Monthly Averaged Direct Normal Radiation (kWh/m<sup>2</sup>/day)

Lat 26.172 Lon -11.088	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Annual Average
22-year Average	5.56	6.14	7.07	7.92	8.00	8.13	7.83	7.26	6.48	5.88	5.49	4.90	6.72

#### Minimum And Maximum Difference From Monthly Averaged Direct Normal Radiation (%)

Lat 26.172 Lon -11.088	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Minimum	-9	-13	-5	-5	-4	-5	-6	-1	-7	-10	-4	-13
Maximum	5	8	4	1	4	5	4	10	4	7	14	17

**NOTE:** Diffuse radiation, direct normal radiation and tilted surface radiation are not calculated when the clearness index (K) is below 0.3 or above 0.8.

**Monthly Averaged Insolation Incident On A Horizontal Surface At Indicated GMT Times (kW/m<sup>2</sup>)**

Lat 26.172 Lon -11.088	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Average@00	n/a											
Average@03	n/a											
Average@06	n/a	0.00	0.00	0.02	0.03	0.04	0.03	0.02	0.01	0.00	0.00	0.00
Average@09	0.16	0.21	0.32	0.43	0.49	0.50	0.46	0.40	0.32	0.27	0.23	0.16
Average@12	0.55	0.64	0.75	0.87	0.89	0.88	0.86	0.85	0.79	0.69	0.59	0.51
Average@15	0.46	0.56	0.70	0.77	0.80	0.79	0.78	0.76	0.68	0.55	0.43	0.39
Average@18	0.05	0.09	0.13	0.17	0.19	0.23	0.25	0.17	0.10	0.05	0.03	0.03
Average@21	n/a	n/a	n/a	n/a	0.00	0.00	0.00	n/a	n/a	n/a	n/a	n/a

[https://eosweb.larc.nasa.gov/cgi-bin/sse/grid.cgi?&num=169117&lat=26.172&submit=Submit&hgt=100&veg=17&sitelev=&email=skip@larc.nasa.gov&p=grid\\_id&p=swvdwncooki&p=midday\\_dwn&p=clrskycooki&p=clrskyday&p...](https://eosweb.larc.nasa.gov/cgi-bin/sse/grid.cgi?&num=169117&lat=26.172&submit=Submit&hgt=100&veg=17&sitelev=&email=skip@larc.nasa.gov&p=grid_id&p=swvdwncooki&p=midday_dwn&p=clrskycooki&p=clrskyday&p...)  
5/28/2017

NASA Surface Meteorology and Solar Energy - Available Tables

[Parameter Definition](#)

**Monthly Averaged Insolation Clearness Index (0 to 1.0)**

Lat 26.172 Lon -11.088	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Annual Average
22-year Average K	0.58	0.60	0.63	0.66	0.66	0.66	0.65	0.64	0.61	0.59	0.57	0.55	0.62
Minimum K	0.53	0.51	0.59	0.62	0.62	0.61	0.60	0.60	0.56	0.52	0.52	0.47	0.56
Maximum K	0.62	0.66	0.67	0.69	0.70	0.71	0.70	0.70	0.64	0.64	0.65	0.63	0.67

[Parameter Definition](#)

**Monthly Averaged Insolation Normalized Clearness Index (0 to 1.0)**

Lat 26.172 Lon -11.088	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
22-year Average	0.53	0.55	0.58	0.61	0.60	0.61	0.60	0.58	0.56	0.54	0.53	0.50

[Parameter Definition](#)

**Monthly Averaged Clear Sky Insolation Incident On A Horizontal Surface (kWh/m<sup>2</sup>/day)**

Lat 26.172 Lon -11.088	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Annual Average
22-year Average	4.28	5.26	6.45	7.52	7.69	7.74	7.31	6.91	6.21	5.33	4.44	3.86	6.08

[Parameter Definition](#)

**Monthly Averaged Clear Sky Insolation Clearness Index (0 to 1.0)**

Lat 26.172 Lon -11.088	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
22-year Average	0.65	0.67	0.70	0.72	0.69	0.68	0.65	0.65	0.64	0.65	0.65	0.63

[Parameter Definition](#)

**Monthly Averaged Clear Sky Insolation Normalized Clearness Index (0 to 1.0)**

Lat 26.172 Lon -11.088	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
22-year Average	0.60	0.62	0.64	0.65	0.63	0.62	0.59	0.59	0.59	0.59	0.59	0.57

[Parameter Definition](#)

[https://eosweb.larc.nasa.gov/cgi-bin/sse/grid.cgi?&num=169117&lat=26.172&submit=Submit&hgt=100&veg=17&sitelev=&email=skip@larc.nasa.gov&p=grid\\_id&p=swvdwncooki&p=midday\\_dwn&p=clrskycooki&p=clrskyday&p...](https://eosweb.larc.nasa.gov/cgi-bin/sse/grid.cgi?&num=169117&lat=26.172&submit=Submit&hgt=100&veg=17&sitelev=&email=skip@larc.nasa.gov&p=grid_id&p=swvdwncooki&p=midday_dwn&p=clrskycooki&p=clrskyday&p...)

**Monthly Averaged Surface Albedo (0 to 1.0)**

Lat 26.172 Lon -11.088	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Annual Average
22-year Average	0.30	0.30	0.30	0.31	0.34	0.36	0.37	0.34	0.31	0.30	0.31	0.30	0.32

*Parameters for Sizing Battery or other Energy-storage Systems:*

**Minimum Available Insolation Over A Consecutive-day Period (%)**

Lat 26.172 Lon -11.088	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Min/1 day	4.19	17.9	24.1	35.8	23.4	22.3	59.5	22.2	43.2	4.34	17.2	14.2
Min/3 day	47.5	37.2	47.7	51.1	59.1	42.3	80.7	62.3	57.8	41.2	54.8	24.4
Min/7 day	69.3	57.6	77.3	66.5	65.9	76.9	89.6	76.7	73.3	61.6	74.1	62.6
Min/14 day	79.1	70.7	83.9	83.3	80.1	83.8	91.4	87.3	84.5	77.1	85.1	74.3
Min/21 day	84.2	78.8	91.3	89.7	85.9	89.3	91.8	92.2	89.1	83.6	89.8	81.3
Min/Month	90.8	85.7	93.3	93.6	93.7	92.7	92.1	94.5	91.9	89.2	91.3	85.2

[\*Parameter Definition\*](#)

**Solar Radiation Deficits Below Expected Values Incident On A Horizontal Surface Over A Consecutive-day Period (kWh/m<sup>2</sup>)**

Lat 26.172 Lon -11.088	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1 day	3.65	3.85	4.47	4.48	5.66	5.87	2.97	5.29	3.33	4.62	3.27	2.90
3 day	6.00	8.83	9.23	10.2	9.05	13.0	4.25	7.68	7.42	8.52	5.35	7.66
7 day	8.17	13.9	9.34	16.3	17.6	12.2	5.32	11.0	10.9	12.9	7.15	8.82
14 day	11.1	19.2	13.2	16.2	20.5	17.0	8.76	12.0	12.6	15.4	8.21	12.1
21 day	12.6	20.8	10.7	15.0	21.8	16.8	12.5	11.0	13.3	16.5	8.39	13.2
Month	10.8	18.7	12.0	13.2	14.2	16.5	17.9	11.4	14.1	16.1	10.2	15.5

**Equivalent Number Of NO-SUN Or BLACK Days (days)**

Lat 26.172 Lon -11.088	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1 day	0.95	0.82	0.75	0.64	0.76	0.77	0.40	0.77	0.56	0.95	0.82	0.85
3 day	1.57	1.88	1.56	1.46	1.22	1.72	0.57	1.12	1.26	1.76	1.35	2.26
7 day	2.14	2.96	1.58	2.34	2.38	1.61	0.72	1.62	1.86	2.68	1.81	2.61
14 day	2.91	4.09	2.25	2.32	2.77	2.25	1.19	1.76	2.16	3.19	2.07	3.59
21 day	3.30	4.44	1.82	2.16	2.95	2.23	1.70	1.62	2.27	3.43	2.12	3.91
Month	2.84	4.00	2.05	1.89	1.92	2.18	2.44	1.68	2.40	3.33	2.58	4.58

**Meteorology (Temperature):**

**Monthly Averaged Air Temperature At 10 m Above The Surface Of The Earth (°C)**

Lat 26.172 Lon -11.088	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Annual Average
22-year Average	14.7	17.0	19.4	20.9	22.6	25.3	28.7	29.1	27.2	24.1	20.0	16.4	22.1
Minimum	9.53	11.1	13.1	14.3	15.8	18.3	20.9	21.9	20.9	18.5	14.8	11.5	15.9
Maximum	20.6	23.4	26.0	27.7	29.5	32.6	37.3	37.4	34.2	30.2	25.6	22.0	28.9

[\*Parameter Definition\*](#)

**Average Daily Temperature Range (°C)**

Lat 26.172 Lon -11.088	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
22-year Average	11.0	12.3	12.8	13.4	13.7	14.3	16.3	15.4 *	13.3	11.7	10.8	10.5

\* Warmest month

**Monthly Averaged Total Column Precipitable Water (cm)**

Lat 26.172 Lon -11.088	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Annual Average
22-year Average	1.05	1.09	1.15	1.29	1.54	1.80	2.12	2.44	2.36	1.98	1.56	1.26	1.64

[\*Parameter Definition\*](#)

**Monthly Averaged Precipitation (mm/day)**

Lat 26.172 Lon -11.088	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Annual Average
22-year Average	0.35	0.34	0.28	0.11	0.06	0.04	0.10	0.24	0.37	0.35	0.36	0.47	0.25

## APPENDIX C: AQUIFER TYPE AND PRODUCTIVITY WITH LOCATION POINT





Figure 1: Aquifer type and productivity with location point

## APPENDIX D: IRRIGATION WATER REQUIREMENT DATA FROM [23]

Table 1: Potential irrigation efficiency and water requirements for 84 zones in Africa (see zone 14)

IWR zone	Irrigation crop zone	Irrigation efficiency %	Irrigation water requirement (mm/year)		IWR zone	Irrigation crop zone	Irrigation efficiency %	Irrigation water requirement (mm/year)	
			Net	Gross				Net	Gross
1	1	60	400	700	43	10	50	350	700
2	1	60	500	850	44	10	50	600	1 200
3	1	60	450	750	45	11	45	550	1 250
4	1	60	800	1 350	46	9	50	500	1 000
5	1	60	700	1 200	47	9	50	400	800
6	1	60	900	1 500	48	9	50	650	1 300
7	2	70	900	1 300	49	9	50	850	1 700
8	1	60	650	1 100	50	4a	45	2 200	4 900
9	1	60	750	1 250	51	4a	45	1 650	3 700
10	5	80	900	1 150	52	4a	45	1 400	3 150
11	5	80	1 000	1 250	53	12a	45	1 250	2 800
12	5	80	1 250	1 600	54	12a	45	900	2 000
13	2	70	900	1 300	55	4b	50	800	1 600
14	2	70	1 250	1 800	56	12a	45	700	1 600
15	2	70	1 600	2 300	57	12a	45	550	1 250
16	2	70	1 200	1 750	58	12a	45	500	1 150
17	7	80	1 400	1 750	59	12b	45	500	1 150
18	7	80	1 200	1 500	60	12b	45	550	1 250
19	7	80	900	1 150	61	12b	45	650	1 450
20	7	80	750	950	62	12b	45	900	2 000
21	3a	50	400	800	63	14	65	200	350
22	3a	50	350	700	64	13	50	300	600
23	3a	50	600	1 200	65	14	65	350	550
24	3a	50	250	500	66	14	65	400	650
25	6	50	350	700	67	14	65	600	950
26	17	50	500	1 000	68	16	60	400	700
27	3a	50	150	300	69	16	60	950	1 600
28	6	50	100	200	70	16	60	800	1 350
29	6	50	250	500	71	16	60	600	1 000
30	3b	50	1 200	2 400	72	16	60	500	850
31	3b	50	750	1 500	73	4d	50	1 000	2 000
32	8	50	750	1 500	74	4e	50	450	900
33	8	50	450	900	75	4d	50	750	1 500
34	3b	50	500	1 000	76	11	45	500	1 150
35	3b	50	850	1 700	77	11	45	550	1 250
36	3b	50	200	400	78	11	45	450	1 000
37	4c	50	1 500	3 000	79	15	60	650	1 100
38	3b	50	350	700	80	18	60	300	500
39	10	50	400	800	81	18	60	1 500	2 500
40	10	50	850	1 700	82	13	50	200	400
41	10	50	350	700	83	18	60	150	250
42	10	50	600	1 200	84	2	70	900	1 300



Inland water body

84 Irrigation water requirement zone





Figure 2: Gross irrigation water requirements for 84 zones in Africa

## APPENDIX E: CALCULATIONS WITH EXCEL

### CASE 2


CALCULATIONS PROJECT		raw water	D1	irrigation water	D2	drinking water
<b>Hydraulics &amp; Balance</b>						
m <sub>r</sub>		7000	77	6054	2022	2.0216
<b>Pumping</b>						
well depth:	75 m	water requirements	7000 liters/day	4032 liters/day	2000 liters/day Q	
additional height	25 m		5 h/day	5 h/day	5 h/day	
head (H):	100 m		1400 liters/h	806.4865 liters/h	400 liters/h	
flow rate (Q):	1.4 m <sup>3</sup> /h		1.4 m <sup>3</sup> /h	0.806486 m <sup>3</sup> /h	0.4 m <sup>3</sup> /h	
density ( $\rho$ )	1007 kg/m <sup>3</sup>		11 g/l	1 g/l	0.2 g/l	
g	9.81 m/s <sup>2</sup>		77 kg/day	4.0 kg/day	0.4 kg/day	
eff	0.75	energy per m <sup>3</sup>				
		power desal.				
		energy for desal.				
Power (hydraulic)	0.384171 kW	Power = $\rho g H$				
Power required	0.512227 kW					
n. hours pumping	5 h/day	(PSSH: 5.94)				
Energy	2.561137 kWh/day					
check	2.543333					
Detailed pressure drop calculations: not required for now, dP losses included in additional height (conservative)						

Method A			Method B		
Energy hydr.	E <sub>h</sub>	2.6 kWh/day	E <sub>h</sub> = $\eta_s E_e = \rho g h V$	A <sub>pv</sub> = $\frac{\rho g h V}{G_T \eta_p \eta_s}$	
Energy desal.	E <sub>des</sub>	14.1 kWh/day	E <sub>s</sub> = $A_{pv} G_T \eta_{pv}$		
Energy dwell.	E <sub>dw</sub>	0.0 kWh/day	P = $A_{pv} G_T \eta_r$	P = 1000 A <sub>pv</sub> $\eta_r$	
Energy other	E <sub>other</sub>	0.0 kWh/day	P = 1000 $\frac{\rho g h V \eta_r}{G_T \eta_p \eta_s}$	$\eta_o = \frac{P_h}{P_m} = \frac{\rho g h V}{A_{pv} G_T}$	
Energy Total	E <sub>T</sub>	16.6 kWh/day			Energy To E <sub>T</sub> 16.6 kWh/day
eff. from Ee	$\eta_s$	0.80			thermal factor F <sub>TH</sub> 0.83
Energy PV	E <sub>e</sub>	20.8 kWh/day			mismatch factor F 0.85
eff. PV	$\eta_{pv}$		$PR = \frac{\eta_{op}}{\eta_{STC}}$		operating factor 0.75
eff. PV ref.	$\eta_r$				battery efficiency $\eta_{BA}$ 0.9
eff. PV ref/PV	$\eta_r / \eta_{pv}$	1.18 1/PR	PR: 0.85		inverter efficiency $\eta_{INV}$ 0.9
Irradiance	G <sub>T</sub> min	4.4 kWh/m <sup>2</sup> /day			pump/motor efficiency $\eta_{Mot}$ 0.84
Power (size)	P	5556.8 Wp	P = 1000 $\frac{\rho g h V \eta_r}{G_T \eta_p \eta_s}$	V (m <sup>3</sup> )	Total efficiency 0.6723
with min G		5.556819 kWp			E <sub>generated</sub> = P <sub>peak</sub> * PSSH * F <sub>th</sub> * $\eta_B$ * $\eta_{Inv}$
	G <sub>T</sub> opt	6.28 kWh/m <sup>2</sup> /day	where, P = PV array power (Wp)		
Power (size)	P	3893.3 Wp	p = density of water (1000 K/m <sup>3</sup> )		
with average G		3.893312 kWp	g = acceleration due to gravity (9.81 m/s <sup>2</sup> )		
	G <sub>T</sub>	5.94 kWh/m <sup>2</sup> /day	h = total pumping head (m)		
Power (size)	P	4116.2 Wp	V = daily water production (m <sup>3</sup> )		
		4.12 kWp	G <sub>T</sub> = daily solar radiation energy on the PV array surface (kWh/m <sup>2</sup> )		
Estimated area		25.0 m <sup>2</sup>	$\eta_r$ = array efficiency at 1000 W/m <sup>2</sup> and 25°C		
			$\eta_{PV}$ = array efficiency (%)		
			$\eta_s$ = subsystem efficiency (%)		
			Specific energy yield: 4.0392 kWh/kWp		
					PSSH 5.94 h
					Power P 4163.3 Wp
					4.16 kWp





Costs							Lifecycle cost no inflation		
							Life (yrs)	TOTAL (25 years)	
<b>Specific Costs of diesel pumps &amp; d.water</b>									
fuel (diesel for pump)	2.56 kWh/day	0.20 €/kWh	0.5122 €/day	95%	177.61 €/year	25	4 440.4	€	
drinkable water	2 m <sup>3</sup>	3.6 €/m <sup>3</sup>	7.2 €/day	100%	2628 €/year	25	65 700.0	€	
							70 140.4	€	
diesel pump			1000 €			10	2 000	€	
diesel generator			1000 €			5	5 000	€	
<b>tank and other costs for irrigation</b>							5 000	€	
maintenance (pumps, borehole, tanks...)							10 000	€	
<b>TOTAL</b>							92 140.4	€	
							3686		
<b>Costs with PV panels, solar pump and desalination</b>									
<u>Main equipment costs</u>									
solar panels	4.12 kWp	700 €/kWp				25	2 881	€	
racks and supports	4.12 kWp	200 €/kWp				25	823	€	
pump	1		2000 €			10	6 000	€	
tanks (and structure/support)	60.22 m <sup>3</sup>	50 €/m <sup>3</sup>				25	3 011	€	
desalination 1 (irrigation)	7 m <sup>3</sup>	800 €/m <sup>3</sup>					5 600	€	
desalination 2 (drinking)	2 m <sup>3</sup>	800 €/m <sup>3</sup>					1 617	€	
batteries	4.12 kWp	500 €/kWp	2058.1			5	10 290	€	
control unit / regulator-controller			1000 €			15	2 000	€	
inverter (DC to AC)			1000 €			15	2 000	€	
pump controller			1000 €			15	2 000	€	
<u>Other equipment costs</u>									
cables	500 m	5 €/m				25	2 500	€	
breaker switches and other electrical							500	€	
piping	300 m	10 €/m				25	3 000	€	
valves							500	€	
borehole drilling (deeper)	50 m	30 €/m	1500			25	1 500	€	
miscellaneous (bolts, screws...)							500	€	
transport							2 000	€	
installation							2 000	€	
commissioning							1 500	€	
security to prevent theft/vandalism							500	€	
maintenance (pumps, borehole, tanks...)							5 000	€	
							55 723.1	€	

Costs	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25
<b>Specific Costs of diesel pumps &amp; water</b>															
fuel (diesel for pump)	289	304	319	335	352	369	388	407	427	449	471	495	520	546	573
drinkable water	4281	4495	4720	4955	5203	5463	5737	6023	6325	6641	6973	7322	7688	8072	8476
diesel pump															2527
diesel generator															2527
tank and other costs for irrigation															3225
maintenance (pumps, borehole, tanks...)	652	684	718	754	792	832	873	917	963	1011	1061	1114	1170	1229	1290
TOTAL	5 221.6	5 482.7	5 756.8	6 044.7	8 326.8	6 664.2	6 997.5	7 947.3	7 714.7	13 154.3	8 505.5	8 930.7	9 377.3	9 846.1	13 563.5
<b>Costs with PV panels, solar pump and desalination</b>															
Main equipment costs	year 11	year 12	year 13	year 14	year 15	year 16	year 17	year 18	year 19	year 20	year 21	year 22	year 23	year 24	year 25
solar panels															5054
racks and supports															
pump															
tanks (and structure/support)															
desalination 1 (irrigation)															
desalination 2 (drinking)															
batteries															4075
control unit / regulator-controller															5201
inverter (DC to AC)															1980
pump controller															1980
Other equipment costs															
cables															
breaker switches and other electrical															
piping															
valves															
borehole drilling (deeper)															
miscellaneous (bolts, screws...)															
transport															
installation															
commissioning															
security to prevent theft/vandalism															
maintenance (pumps, borehole, tanks...)	326	342	359	377	396	416	437	458	481	505	531	557	585	614	645
	326	342	359	377	10411	416	437	458	481	10760	531	557	585	614	645
fuel (diesel for pump)	4895.8	5140.6	5397.7	5667.5	-2083.8	6248.5	6569.8	6888.9	7233.4	7394.4	7374.8	7370.5	7379.2	9231.8	12918.5
gas	38221.3	43351.9	48759.5	54427.1	52343.5	58821.7	65152.6	72041.5	79274.9	81659.3	88644.1	88017.6	10589.8	118041.6	128960.1
	-2730.5	-7871.2	-13268.8	-18956.3	-16852.5	-23101.0	-29661.9	-36550.8	-43784.2	-46178.5	-54159.3	-62526.5	-71819.1	-80550.9	-93469.4
0.056652 0.062971 0.161428 0.245791 0.361772 0.287626 0.354567 0.411733 0.461064 0.536116 0.515132 0.552486 0.585404 0.614599 0.624619	2730.5	7871.2	13268.8	18956.3	16852.5	23101.0	29661.9	36550.8	43784.2	46178.5	54153.3	62526.9	71319.1	80550.9	93469.4




Economic analysis															
Simple Payback (yrs) = $\frac{\text{Cost of installed system}}{\text{Net annual cash inflow}}$															
Payback															
Cost of installed system															
net annual cash flow															
SPB (no inflation, first year ref.)															
PB (with inflation)															
NPV(i, N) = $\sum_{t=0}^N \frac{R_t}{(1+i)^t}$															
Net Present Value NPV															
i	0.05														
N	25 years														
initial investment	-35 491														
Years 1-5 CF	3006	3156	3314	3479	2367										
Years 6-10 CF	3836	4028	4229	4441	1470										
Years 11-15 CF	4896	5141	5398	5668	-2084										
Years 16-20 CF	6248	6561	6889	7233	2394										
Years 21-25 CF	7975	8374	8792	9232	12919										
NPV	EUR 26 886.87														
Internal rate of return															
NPV must be equal to 0 (check)															
IRR	0.104126481	10.41%													





CO <sub>2</sub>				PVSYST V6.63	24/08/17	Page 6/6
<b>Produced</b>				Stand Alone System: CO <sub>2</sub> Balance		
350 kgCO <sub>2</sub> /kWp	4.12 kWp	1.4 tCO <sub>2</sub>	(panels and supports) (batteries) (others: tanks, piping...)	Project : Stand Alone Project at Mehaires		
88 gCO <sub>2</sub> eq/kWh	16.63 kWh/day	365 day/year	25 years	Simulation variant : Case 2 august		
13.4 tCO <sub>2</sub>		(PV system)		Simulation for the first year of operation		
10.0 tCO <sub>2</sub>		(others)				
23.4						
<b>Replaced compared to typical grid in Africa</b>						
648 gCO <sub>2</sub> /kWh	16.63 kWh/day	365 day/year	25 years			
98.3 tCO <sub>2</sub>						
Replaced compared to diesel pumps (and alternative water extraction)						
780 gCO <sub>2</sub> /kWh	16.63 kWh/day	365 day/year	25 years			
118.3 tCO <sub>2</sub>						
<b>Saved</b>						
75.0 tCO <sub>2</sub>	compared to grid					
95.0	compared to diesel					
<b>System Lifecycle Emissions Details:</b>						
Item		Modules		Supports		
LCE		343 kgCO <sub>2</sub> /kWp		4.40 kgCO <sub>2</sub> /kg		
Quantity		15.0 kWp		560 kg		
Subtotal [kgCO <sub>2</sub> ]		5138		2465		

### CASE 3




Dwelling consumptions					
	W	h/day	kWh/day	days/year	kWh/year
fridge	150	24	3.6	365	1314
tv and/or computer	200	5	1	365	365
washing machine	1000	1	1	365	365
air conditioning/boiler	1000	6	6	365	2190
electrical cook	0	0.5	0	365	0
lights	50	8	0.4	365	146
oven/microwave/other	1000	0.5	0.5	365	182.5
other					
			12.5		4562.5
number of houses	1		12.5 kWh/day		4562.5

Method A				Method B			
Energy hydr.	E <sub>h</sub>	2.6	kWh/day	E <sub>h</sub> = η <sub>z</sub> E <sub>a</sub> = ρghV	A <sub>pv</sub> = $\frac{\rho ghV}{G_T \eta_{pv} \eta_z}$		
Energy desal.	E <sub>des</sub>	14.1	kWh/day	E <sub>a</sub> = A <sub>pv</sub> G <sub>T</sub> η <sub>pv</sub>			
Energy dwell.	E <sub>dw</sub>	12.5	kWh/day	P = A <sub>pv</sub> G <sub>T</sub> η <sub>z</sub> , P = 1000 A <sub>pv</sub> η <sub>z</sub>			
Energy other	E <sub>other</sub>	0.0	kWh/day	P = 1000 $\frac{\rho ghV \eta_z}{G_T \eta_{pv} \eta_z}$	η <sub>o</sub> = $\frac{P_h}{P_m} = \frac{\rho ghV}{A_{pv} G_T}$		
Energy Total	E <sub>T</sub>	29.1	kWh/day			Energy To	E <sub>T</sub> 29.1 kWh/day
eff. from Ee	η <sub>s</sub>	0.80				thermal factor	F <sub>TH</sub> 0.83
Energy PV	E <sub>e</sub>	36.4	kWh/day			mismatch factor	F 0.85
eff. PV	η <sub>pv</sub>			PR = $\frac{\eta_{op}}{\eta_{STC}}$	P [Wp] = 1000 $\left[ \frac{W}{m^2} \right] \times \frac{Ee [kWh]}{G_T \left[ \frac{kWh}{m^2} \right] \times PR}$	operating factor	0.75
eff. PV ref.	η <sub>r</sub>					battery efficiency	η <sub>BA</sub> 0.9
eff. PV ref/PV	η <sub>r</sub> / η <sub>pv</sub>	1.18	1/PR	PR: 0.85		inverter efficiency	η <sub>INV</sub> 0.9
Irradiance	G <sub>T</sub> min	4.4	kWh/m <sup>2</sup> /day	P = 1000 $\frac{\rho ghV \eta_r}{G_T \eta_{PV} \eta_s}$	V (m <sup>3</sup> )	pump/motor efficiency	η <sub>Mot</sub> 0.84
Power (size) with min G	P	9734.6 Wp		where, P = PV array power (Wp)		Total efficiency	0.6723
		9.734626 kWp		ρ = density of water (1000 K/m <sup>3</sup> )			
				g = acceleration due to gravity (9.81 m/s <sup>2</sup> )			
G <sub>T</sub> opt		6.28	kWh/m <sup>2</sup> /day	h = total pumping head (m)			
Power (size) with average G	P	6820.4 Wp		G <sub>T</sub> = daily solar radiation energy on the PV array surface (kWh/m <sup>2</sup> )		E <sub>generated</sub> = P <sub>peak</sub> * PSSH * F <sub>th</sub> * η <sub>b</sub> * η <sub>inv</sub>	
		6.820439 kWp		η <sub>r</sub> = array efficiency at 1000 W/m <sup>2</sup> and 25°C			
G <sub>T</sub>		5.94	kWh/m <sup>2</sup> /day	η <sub>pv</sub> = array efficiency (%)			
Power (size)	P	7210.8 Wp		η <sub>s</sub> = subsystem efficiency (%)		PSSH	5.94 h
		7.21 kWp				Power	P 7293.4 Wp
Estimated area		43.8 m <sup>2</sup>		Specific energy yield:	4.0392 kWh/kWp		7.29 kWp

## CALCULATIONS PROJECT


### Overall




	1.4 m <sup>3</sup> /h	7000 liters/day	968 liters/day	2000 liters/day	4032 liters/day
	0.512 kW		72.6 kg/day		
	5.00 h/day		2.4 kW	0.4 kW	
12.5 kWh/day	29.1 kWh/day	2.6 kWh/day	14.1 kWh/day		
	36.4 kWh/day				
	7.21 kWp				
	43.8 m <sup>2</sup>				

Economic analysis					
<i>Simple Payback (yrs) = <math>\frac{\text{Cost of installed system}}{\text{Net annual cash inflow}}</math></i>					Payback
Cost of installed system <b>39823</b>					net annual cash flow <b>3006</b>
SPB (no inflation, first year ref.) <b>13.2 years</b>					PB (with inflation) <b>12.0 years</b>
$NPV(i, N) = \sum_{t=0}^N \frac{R_t}{(1+i)^t}$					
Net Present Value NPV	i 0.05	N 25 years	initial investment -39 823	Years 1-5 CF 3006 Years 6-10 CF 3836 Years 11-15 CF 4896 Years 16-20 CF 6248 Years 21-25 CF 7975	3156 4028 5141 6561 8374
				3314 4229 5398 6889 8792	3479 4441 5668 7233 9232
					486 -930 -5147 -1516 12919
	NPV <b>EUR 17 146.72</b>				
Internal rate of return					
NPV must be equal to 0 (check) <b>-EUR 0.00</b>					
IRR <b>0.082580449</b> <b>8.26%</b>					
<u>CO<sub>2</sub></u>					
Produced					
350 kgCO <sub>2</sub> /kWp	7.21 kWp	2.5 tCO <sub>2</sub>	(panels and supports) (batteries) (others: tanks, piping...)		
88 gCO <sub>2</sub> eq/kWh	29.13 kWh/day	365 day/year	25 years		
23.4 tCO <sub>2</sub>			(PV system)		
10.0 tCO <sub>2</sub>			(others)		
<b>33.4</b>					
Replaced compared to typical grid in Africa					
648 gCO <sub>2</sub> /kWh	29.13 kWh/day	365 day/year	25 years		
172.2 tCO <sub>2</sub>					
Replaced compared to diesel pumps (and alternative water extraction)					
780 gCO <sub>2</sub> /kWh	29.13 kWh/day	365 day/year	25 years		
<b>207.3 tCO<sub>2</sub></b>					
Saved					
138.8 tCO <sub>2</sub>	compared to grid				
<b>173.9</b>	compared to diesel				

## CASE 6



Method A				Method B			
Energy hydr.	E <sub>h</sub>	4.7 kWh/day	E <sub>h</sub> = η <sub>z</sub> E <sub>a</sub> = ρghV	A <sub>pv</sub>	= $\frac{\rho g h V}{G_T \eta_{pv} \eta_z}$		
Energy desal.	E <sub>des</sub>	24.1 kWh/day	E <sub>des</sub> = A <sub>pv</sub> G <sub>T</sub> η <sub>pv</sub>				
Energy dwell.	E <sub>dw</sub>	12.5 kWh/day	P = A <sub>pv</sub> G <sub>T</sub> η <sub>r</sub>	P	= 1000 A <sub>pv</sub> η <sub>r</sub>		
Energy other	E <sub>other</sub>	0.0 kWh/day	P = 1000 $\frac{\rho g h V \eta_r}{G_T \eta_{pv} \eta_z}$	η <sub>o</sub>	= $\frac{P_h}{P_m} = \frac{\rho g h V}{A_{pv} G_T}$		
Energy Total	E <sub>T</sub>	41.3 kWh/day				E <sub>T</sub>	41.3 kWh/day
eff. from Ee	η <sub>s</sub>	0.80				thermal factor	F <sub>TH</sub>
Energy PV	E <sub>e</sub>	51.6 kWh/day				mismatch factor	F
eff. PV	η <sub>pv</sub>		PR = $\frac{\eta_{top}}{\eta_{STC}}$	P [Wp] = $1000 \left[ \frac{W}{m^2} \right] \times \frac{Ee [kWh]}{G_T \left[ \frac{kWh}{m^2} \right] \times PR}$	V (m <sup>3</sup> )	operating factor	0.75
eff. PV ref.	η <sub>r</sub>					battery efficiency	η <sub>BA</sub>
eff. PV ref/PV	η <sub>r</sub> / η <sub>pv</sub>	1.18	1/PR	PR: 0.85		inverter efficiency	η <sub>INV</sub>
Irradiance	G <sub>T</sub> min	4.4 kWh/m <sup>2</sup> /day	P = 1000 $\frac{\rho g h V \eta_r}{G_T \eta_{pv} \eta_z}$			pump/motor efficiency	η <sub>Mot</sub>
Power (size)	P	13797.0 Wp				Total efficiency	0.6723
with min G		13.79696 kWp	where, P = PV array power (Wp)			E <sub>generated</sub> = P <sub>peak</sub> * PSSH * F <sub>th</sub> * η <sub>b</sub> * η <sub>inv</sub>	
	G <sub>T</sub> opt	6.28 kWh/m <sup>2</sup> /day	ρ = density of water (1000 K/m <sup>3</sup> )				
Power (size)	P	9666.7 Wp	g = acceleration due to gravity (9.81 m/s <sup>2</sup> )				
with average G		9.666663 kWp	h = total pumping head (m)				
	G <sub>T</sub>	5.94 kWh/m <sup>2</sup> /day	V = daily water production (m <sup>3</sup> )				
Power (size)	P	10220.0 Wp	G <sub>T</sub> = daily solar radiation energy on the PV array surface (kWh/m <sup>2</sup> )				
		10.22 kWp	η <sub>r</sub> = array efficiency at 1000 W/m <sup>2</sup> and 25°C				
Estimated area		62.0 m <sup>2</sup>	η <sub>pv</sub> = array efficiency (%)				
			η <sub>b</sub> = subsystem efficiency (%)				
			Specific energy yield: 4.0392 kWh/kWp			PSSH	5.94 h
						Power	P 10337.0 Wp
							10.34 kWp



Costs	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25						
<b>Specific costs of diesel pumps &amp; d. water</b>																					
fuel (diesel for pump)	year 11	year 12	year 13	year 14	year 15	year 16	year 17	year 18	year 19	year 20	year 21	year 22	year 23	year 24	year 25						
fuel (diesel for pump)	529	555	585	612	643	675	709	744	782	821	862	905	950	998	1047						
drinkable water	4281	4495	4720	4955	5203	5463	5737	6023	6325	6641	6973	7322	7688	8072	8476						
4810	5050	5303	5568	5846	6139	6446	6768	7106	7462	7835	8226	8638	9070	9523							
diesel pump																2527					
diesel generator																2527					
tank and other costs for irrigation																		3225			
maintenance (pumps, borehole, tanks..)	652	684	718	754	792	832	873	917	963	1011	1061	1114	1170	1229	1290						
TOTAL	5 461.3	5 734.4	6 021.1	6 322.2	8 618.2	9 697.2	7 318.7	7 684.6	8 068.9	13 526.2	8 895.9	9 340.7	9 807.8	10 296.1	14 038.2						
<b>Costs with PV panels, solar pump and desalination</b>																					
Main equipment costs	year 11	year 12	year 13	year 14	year 15	year 16	year 17	year 18	year 19	year 20	year 21	year 22	year 23	year 24	year 25						
solar panels																5054					
racks and supports																					
pump																					
tanks (and structure/support)																					
desalination 1 (irrigation)																					
desalination 2 (drinking)																					
batteries																					
control unit / regulator-controller																					
inverter (DC to AC)																					
pump controller																					
Other equipment costs																					
cables																					
breaker switches and other electrical																					
piping																					
valves																					
borehole drilling (deeper)																					
miscellaneous (bolts, screws..)																					
transport																					
installation																					
commissioning																					
security to prevent theft/vandalism																					
maintenance (pumps, borehole, tanks..)	326	342	359	377	396	416	437	458	481	505	531	557	585	614	645						
	326	342	359	377	16453	416	437	458	481	18472	531	557	585	614	645						
fuel (diesel for pump)	5135.5	5392.3	5661.9	5945.0	-7835.0	6554.6	6882.1	7226.2	7587.5	-4945.8	8365.3	8783.5	9222.7	9683.8	13393.1						
gas	31867.9	37260.2	42922.2	48867.2	41032.4	47856.6	54468.8	61695.0	69282.5	64358.8	72702.0	81485.6	90708.3	100392.1	113785.3						
	18971.4	13579.1	7917.1	1972.1	9807.1	3252.7	-3629.4	-10855.7	-18443.2	-13497.5	-21862.7	-30646.3	-39869.0	-49552.8	-62945.9						
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-						
	-18971.4	-13579.1	-7917.1	-1972.1	-9807.1	-3252.7	3629.4	10855.7	18443.2	13497.5	21862.7	30646.3	39869.0	49552.8	62945.9						

Economic analysis	
	$\text{Simple Payback (yrs)} = \frac{\text{Cost of installed system}}{\text{Net annual cash inflow}}$
Payback	
Cost of installed system	50839
net annual cash flow	3153
SPB (no inflation, first year ref.)	16.1 years
PB (with inflation)	16.1 years
Net Present Value NPV	$NPV(i, N) = \sum_{t=0}^N \frac{R_t}{(1+i)^t}$
i	0.05
N	25 years
Initial investment	-50839
Years 1-5 CF	3153 3310 3476 3650 -1163
Years 6-10 CF	4024 4225 4436 4658 -7835
Years 11-15 CF	5136 5392 5662 5945 -7835
Years 16-20 CF	6554 6882 7226 7588 -4946
Years 21-25 CF	8365 8784 9223 9684 13393
NPV	EUR 4 533.61
Internal rate of return	
NPV must be equal to 0 (check)	EUR 0.00
IRR	0.057277275 5.73%

<u>CO<sub>2</sub></u>				
<b>Produced</b>				
350 kgCO <sub>2</sub> /kWp	10.22 kWp	3.6 tCO <sub>2</sub>	(panels and supports) (batteries) (others: tanks, piping...)	
88 gCO <sub>2</sub> eq/kWh	41.28 kWh/day	365 day/year	25 years	
33.1 tCO <sub>2</sub>			(PV system)	
10.0 tCO <sub>2</sub>			(others)	
43.1				
<b>Replaced compared to typical grid in Africa</b>				
648 gCO <sub>2</sub> /kWh	41.28 kWh/day	365 day/year	25 years	
244.1 tCO <sub>2</sub>				
<b>Replaced compared to diesel pumps (and alternative water extraction)</b>				
780 gCO <sub>2</sub> /kWh	41.28 kWh/day	365 day/year	25 years	
293.8 tCO <sub>2</sub>				
<b>Saved</b>				
200.9 tCO <sub>2</sub>	compared to grid			
250.7	compared to diesel			

## APPENDIX F: CALCULATIONS WITH PVSYSTS

### CASE 2

PVSYST V6.63		24/08/17	Page 1/6
Stand Alone System: Simulation parameters			
<b>Project :</b>	<b>Stand Alone Project at Mehaires</b>		
<b>Geographical Site</b>	Mehaires	Country	Western Sahara
<b>Situation</b>	Latitude 26.17° N	Longitude -11.09° W	
Time defined as	Legal Time	Time zone UT	Altitude 375 m
	Albedo	0.20	
<b>Meteo data:</b>	Mehaires	NASA-SSE satellite data, 1983-2005 - Synthetic	
<b>Simulation variant :</b>	<b>Case 2 august</b>		
	Simulation date	24/08/17 18h10	
	Simulation for the	first year of operation	
<b>Simulation parameters</b>			
<b>Collector Plane Orientation</b>	Tilt 25°	Azimuth 0°	
<b>Models used</b>	Transposition Perez	Diffuse Perez, Meteonorm	
<b>PV Array Characteristics</b>			
<b>PV module</b>	Si-poly Model REC 300PE 72		
Original PVsyst database	Manufacturer REC		
Number of PV modules	In series 2 modules	In parallel 7 strings	
Total number of PV modules	Nb. modules 14	Unit Nom. Power 300 Wp	
Array global power	Nominal (STC) 4200 Wp	At operating cond. 3781 Wp (50°C)	
Array operating characteristics (50°C)	U mpp 66 V	I mpp 57 A	
Total area	Module area 27.3 m²	Cell area 24.5 m²	
<b>PV Array loss factors</b>			
Thermal Loss factor	Uc (const) 20.0 W/m²K	Uv (wind) 0.0 W/m²K / m/s	
Wiring Ohmic Loss	Global array res. 19 mOhm	Loss Fraction 1.5 % at STC	
Serie Diode Loss	Voltage Drop 0.7 V	Loss Fraction 1.0 % at STC	
LID - Light Induced Degradation		Loss Fraction 1.5 %	
Module Quality Loss		Loss Fraction -0.4 %	
Module Mismatch Losses		Loss Fraction 1.0 % at MPP	
Module average degradation	Year no 1	Loss factor 0.4 %/year	
Mismatch due to degradation	Imp dispersion RMS 0.4 %/year	Voc dispersion RMS 0.4 %/year	
Incidence effect, ASHRAE parametrization	IAM = 1 - bo (1/cos i - 1)	bo Param. 0.05	
<b>System Parameter</b>	System type	<b>Stand Alone System</b>	
<b>Battery</b>	Model Solar 12V / 160 Ah		
	Manufacturer Generic		
Battery Pack Characteristics	Voltage 48 V	Nominal Capacity 480 Ah	
	Nb. of units 4 in series x 3 in parallel		
	Temperature External ambient temperature		
<b>Controller</b>	Model FLEXmax 60 - 48V		
	Manufacturer Outback		
	Technology MPPT converter	Temp coeff. -5.0 mV/°C/elec.	
Converter	Maxi and EURO efficiencies 98.1/96.8 %		
Battery management control	Treshold commands as	Battery voltage	
	Charging 54.0 / 50.1 V	Corresp. SOC 0.90 / 0.75	
	Discharging 47.1 / 48.9 V	Corresp. SOC 0.20 / 0.45	
<b>User's needs :</b>	Daily household consumers average	Constant over the year 16.6 kWh/Day	

### Stand Alone System: Detailed User's needs


**Project :** Stand Alone Project at Mehaires  
**Simulation variant :** Case 2 august  
 Simulation for the first year of operation

Main system parameters	System type	Stand alone		
PV Field Orientation	tilt	25°	azimuth	0°
PV modules	Model	REC 300PE 72	Pnom	300 Wp
PV Array	Nb. of modules	14	Pnom total	4200 Wp
Battery	Model	Solar 12V / 160 Ah	Technology	sealed, Gel
battery Pack	Nb. of units	12	Voltage / Capacity	48 V / 480 Ah
User's needs	Daily household consumers	Constant over the year	global	6071 kWh/year

**Daily household consumers, Constant over the year, average = 16.6 kWh/day**

**Annual values**

	Number	Power	Use	Energy
Other uses	1	2772 W tot	6 h/day	16632 Wh/day
Total daily energy				16632 Wh/day




### Stand Alone System: Main results

**Project :** Stand Alone Project at Mehaires  
**Simulation variant :** Case 2 august  
 Simulation for the first year of operation

Main system parameters	System type	Stand alone		
PV Field Orientation	tilt	25°	azimuth	0°
PV modules	Model	REC 300PE 72	Pnom	300 Wp
PV Array	Nb. of modules	14	Pnom total	4200 Wp
Battery	Model	Solar 12V / 160 Ah	Technology	sealed, Gel
battery Pack	Nb. of units	12	Voltage / Capacity	48 V / 480 Ah
User's needs	Daily household consumers	Constant over the year	global	6071 kWh/year

Main simulation results	Available Energy	7.67 MWh/year	Specific prod.	1825 kWh/kWp/year
System Production	Used Energy	6.01 MWh/year	Excess (unused)	1.44 MWh/year
	Performance Ratio PR	63.32 %	Solar Fraction SF	99.07 %
Loss of Load	Time Fraction	0.5 %	Missing Energy	0.06 MWh/year
Investment	Global incl. taxes	13895 €	Specific	3.31 €/Wp
Yearly cost	Annuities (Loan 5.0%, 20 years)	1115 €/yr	Running Costs	7037 €/yr
Energy cost		1.36 €/kWh		



Case 2 august  
 Balances and main results

	GlobHor kWh/m²	GlobEff kWh/m²	E Avail MWh	E Unused MWh	E Miss MWh	E User MWh	E Load MWh	SolFrac
January	118.1	160.4	0.585	0.051	0.000	0.516	0.516	1.000
February	151.3	162.2	0.581	0.090	0.000	0.466	0.466	1.000
March	182.6	203.2	0.714	0.179	0.000	0.516	0.516	1.000
April	209.4	206.8	0.720	0.207	0.000	0.499	0.499	1.000
May	229.1	206.1	0.717	0.183	0.000	0.516	0.516	1.000
June	226.8	196.1	0.678	0.158	0.000	0.499	0.499	1.000
July	227.8	202.0	0.686	0.149	0.000	0.516	0.516	1.000
August	210.8	201.6	0.682	0.147	0.000	0.516	0.516	1.000
September	176.1	186.5	0.635	0.127	0.000	0.499	0.499	1.000
October	149.7	177.1	0.610	0.076	0.003	0.513	0.516	0.995
November	118.5	154.5	0.544	0.044	0.007	0.492	0.499	0.986
December	104.8	143.0	0.515	0.028	0.047	0.468	0.516	0.909
Year	2085.0	2199.4	7.667	1.440	0.057	6.014	6.071	0.991

Legends: GlobHor : Horizontal global irradiation  
 GlobEff : Effective Global, corr. for IAM and shadings  
 E Avail : Available Solar Energy  
 E Unused : Unused energy (full battery) loss


E Miss : Missing energy  
 E User : Energy supplied to the user  
 E Load : Energy need of the user (Load)  
 SolFrac : Solar fraction (EUsed / ELoad)

### Stand Alone System: Loss diagram

**Project :** Stand Alone Project at Mehaires  
**Simulation variant :** Case 2 august  
 Simulation for the first year of operation

Main system parameters	System type	Stand alone		
PV Field Orientation	tilt	25°	azimuth	0°
PV modules	Model	REC 300PE 72	Pnom	300 Wp
PV Array	Nb. of modules	14	Pnom total	4200 Wp
Battery	Model	Solar 12V / 160 Ah	Technology	sealed, Gel
battery Pack	Nb. of units	12	Voltage / Capacity	48 V / 480 Ah
User's needs	Daily household consumers	Constant over the year	global	6071 kWh/year

#### Loss diagram over the whole year



### Stand Alone System: Economic evaluation

**Project :** Stand Alone Project at Mehaires

**Simulation variant :** Case 2 august

Simulation for the first year of operation

Main system parameters	System type	Stand alone		
PV Field Orientation	tilt	25°	azimuth	0°
PV modules	Model	REC 300PE 72	Pnom	300 Wp
PV Array	Nb. of modules	14	Pnom total	4200 Wp
Battery	Model	Solar 12V / 160 Ah	Technology	sealed, Gel
battery Pack	Nb. of units	12	Voltage / Capacity	48 V / 480 Ah
User's needs	Daily household consumers	Constant over the year	global	6071 kWh/year

#### Investment

PV modules (Pnom = 300 Wp)	14 units	202 € / unit	2828 €
Supports / Integration		83 € / module	1167 €
Batteries ( 12 V / 160 Ah)	12 units	174 € / unit	2088 €
regulator			5000 €
Settings, wiring, ...			1000 €
Substitution underworth			0 €
<b>Gross investment (without taxes)</b>			<b>12083 €</b>

#### Financing

Gross investment (without taxes)		12083 €
Taxes on investment (VAT)	Rate 15.0 %	1812 €
Gross investment (including VAT)		13895 €
Subsidies		0 €
<b>Net investment (all taxes included)</b>		<b>13895 €</b>
Annuities	( Loan 5.0 % over 20 years)	1115 €/year
Maintenance		0 €/year
insurance, annual taxes		0 €/year
Provision for battery replacement	(lifetime 100.0 years)	7037 €/year
<b>Total yearly cost</b>		<b>8152 €/year</b>

#### Energy cost

Used solar energy	6014 kWh / year
Excess energy (battery full)	1440 kWh / year
Used energy cost	1.36 € / kWh

### Stand Alone System: CO2 Balance

**Project :** Stand Alone Project at Mehaires

**Simulation variant :** Case 2 august

Simulation for the first year of operation

Main system parameters	System type	Stand alone		
PV Field Orientation	tilt	25°	azimuth	0°
PV modules	Model	REC 300PE 72	Pnom	300 Wp
PV Array	Nb. of modules	14	Pnom total	4200 Wp
Battery	Model	Solar 12V / 160 Ah	Technology	sealed, Gel
battery Pack	Nb. of units	12	Voltage / Capacity	48 V / 480 Ah
User's needs	Daily household consumers	Constant over the year	global	6071 kWh/year

**Produced Emissions** Total: 7.60 tCO2

Source: Detailed calculation from table below

**Replaced Emissions** Total: 122.8 tCO2

System production: 7666.72 kWh/yr Lifetime: 30 years

Annual Degradation: 1.0 %


Grid Lifecycle Emissions: 534 gCO2/kWh

Source: IEA List Country: World

**CO2 Emission Balance** Total: 99.0 tCO2

#### System Lifecycle Emissions Details:

Item	Modules	Supports
LCE	343 kgCO2/kWp	4.40 kgCO2/kg
Quantity	15.0 kWp	560 kg
Subtotal [kgCO2]	5138	2465



CASE 3

PVSYST V6.63		28/08/17	Page 1/6
<b>Stand Alone System: Simulation parameters</b>			
<b>Project :</b>	<b>Stand Alone Project at Mehaires</b>		
<b>Geographical Site</b>	<b>Mehaires</b>		
<b>Situation</b>	Latitude	26.17 °N	Longitude -11.09 °W
Time defined as	Legal Time	Time zone UT	Altitude 375 m
	Albedo	0.20	
<b>Meteo data:</b>	<b>Mehaires</b>	NASA-SSE satellite data, 1983-2005 - Synthetic	
<b>Simulation variant :</b>	<b>Case 3 august 02 consumptions</b>		
	Simulation date	28/08/17 17h28	
	Simulation for the	<b>first year of operation</b>	
<b>Simulation parameters</b>			
<b>Collector Plane Orientation</b>	Tilt	25°	Azimuth 0°
<b>Models used</b>	Transposition	Perez	Diffuse Perez, Meteonorm
<b>PV Array Characteristics</b>			
<b>PV module</b>	Si-poly	Model REC 300PE 72	
Original PVsyst database		Manufacturer REC	
Number of PV modules	In series	2 modules	In parallel 12 strings
Total number of PV modules	Nb. modules	24	Unit Nom. Power 300 Wp
Array global power	Nominal (STC)	7.20 kWp	At operating cond. 6.48 kWp (50°C)
Array operating characteristics (50°C)	U mpp	66 V	I mpp 98 A
Total area	Module area	46.8 m <sup>2</sup>	Cell area 42.1 m <sup>2</sup>
<b>PV Array loss factors</b>			
Thermal Loss factor	Uc (const)	20.0 W/m <sup>2</sup> K	Uv (wind) 0.0 W/m <sup>2</sup> K / m/s
Wiring Ohmic Loss	Global array res.	11 mOhm	Loss Fraction 1.5 % at STC
Series Diode Loss	Voltage Drop	0.7 V	Loss Fraction 1.0 % at STC
LID - Light Induced Degradation			Loss Fraction 1.5 %
Module Quality Loss			Loss Fraction -0.4 %
Module Mismatch Losses			Loss Fraction 1.0 % at MPP
Module average degradation	Year no	1	Loss factor 0.4 %/year
Mismatch due to degradation	Imp dispersion RMS	0.4 %/year	Voc dispersion RMS 0.4 %/year
Incidence effect, ASHRAE parametrization	IAM =	1 - bo (1/cos i - 1)	bo Param. 0.05
<b>System Parameter</b>	System type	<b>Stand Alone System</b>	
<b>Battery</b>	Model Solar 12V / 160 Ah		
	Manufacturer Generic		
<b>Battery Pack Characteristics</b>	Voltage 48 V	Nominal Capacity 480 Ah	
	Nb. of units 4 in series x 3 in parallel		
	Temperature External ambient temperature		
<b>Controller</b>	Model FLEXmax 80 - 48V		
	Manufacturer Outback		
	Technology MPPT converter	Temp coeff. -5.0 mV/°C/elec.	
<b>Converter</b>	Maxi and EURO efficiencies 97.5/96.3 %		
<b>Battery management control</b>	Treshold commands as	Battery voltage	
	Charging 54.7 / 50.1 V	Corresp. SOC 0.90 / 0.75	
	Discharging 47.0 / 48.9 V	Corresp. SOC 0.20 / 0.45	
<b>User's needs :</b>	Daily household consumers average	Constant over the year 29.1 kWh/Day	

### Stand Alone System: Detailed User's needs


**Project :** Stand Alone Project at Mehaires  
**Simulation variant :** Case 3 august 02 consumptions  
 Simulation for the first year of operation

Main system parameters	System type	Stand alone		
PV Field Orientation	tilt	25°	azimuth	0°
PV modules	Model	REC 300PE 72	Pnom	300 Wp
PV Array	Nb. of modules	24	Pnom total	7.20 kWp
Battery	Model	Solar 12V / 160 Ah	Technology	sealed, Gel
battery Pack	Nb. of units	12	Voltage / Capacity	48 V / 480 Ah
User's needs	Daily household consumers	Constant over the year	global	10.63 MWh/year

**Daily household consumers, Constant over the year, average = 29.1 kWh/day**

#### Annual values

	Number	Power	Use	Energy
Lamps (LED or fluo)	1	50 W/lamp	8 h/day	400 Wh/day
TV / PC / Mobile	1	200 W/app	5 h/day	1000 Wh/day
Domestic appliances	1	1000 W/app	6 h/day	6000 Wh/day
Fridge / Deep-freeze	1		24 Wh/day	3600 Wh/day
Dish- & Cloth-washers	1		1 Wh/day	1000 Wh/day
Other uses	1	2771 W tot	6 h/day	16626 Wh/day
Other uses	1	1000 W tot	1 h/day	500 Wh/day
Total daily energy				29126 Wh/day





### Stand Alone System: Main results

**Project :** Stand Alone Project at Mehaires  
**Simulation variant :** Case 3 august 02 consumptions  
 Simulation for the first year of operation

Main system parameters	System type	Stand alone		
PV Field Orientation	tilt	25°	azimuth	0°
PV modules	Model	REC 300PE 72	Pnom	300 Wp
PV Array	Nb. of modules	24	Pnom total	7.20 kWp
Battery	Model	Solar 12V / 160 Ah	Technology	sealed, Gel
battery Pack	Nb. of units	12	Voltage / Capacity	48 V / 480 Ah
User's needs	Daily household consumers	Constant over the year	global	10.63 MWh/year

#### Main simulation results

System Production	Available Energy	12.87 MWh/year	Specific prod.	1787 kWh/kWp/year
	Used Energy	10.36 MWh/year	Excess (unused)	2.26 MWh/year
Loss of Load	Performance Ratio PR	63.66 %	Solar Fraction SF	97.50 %
	Time Fraction	1.1 %	Missing Energy	0.27 MWh/year
Investment	Global incl. taxes	17176 €	Specific	2.39 €/Wp
Yearly cost	Annuities (Loan 5.0%, 20 years)	1378 €/yr	Running Costs	7037 €/yr
Energy cost		0.81 €/kWh		



Case 3 august 02 consumptions  
 Balances and main results

	GlobHor kWh/m²	GlobEff kWh/m²	E Avail MWh	E Unused MWh	E Miss MWh	E User MWh	E Load MWh	SolFrac
January	118.1	160.4	0.981	0.079	0.009	0.894	0.903	0.990
February	151.3	162.2	0.968	0.137	0.000	0.816	0.816	1.000
March	182.6	203.2	1.186	0.264	0.000	0.903	0.903	1.000
April	209.4	206.8	1.184	0.290	0.000	0.874	0.874	1.000
May	229.1	206.1	1.199	0.271	0.005	0.898	0.903	0.995
June	226.8	196.1	1.149	0.252	0.000	0.874	0.874	1.000
July	227.8	202.0	1.168	0.262	0.028	0.875	0.903	0.969
August	210.8	201.6	1.159	0.254	0.028	0.875	0.903	0.969
September	176.1	186.5	1.070	0.198	0.018	0.855	0.874	0.979
October	149.7	177.1	1.023	0.132	0.037	0.865	0.903	0.959
November	118.5	154.5	0.912	0.072	0.043	0.830	0.874	0.950
December	104.8	143.0	0.866	0.050	0.098	0.805	0.903	0.891
Year	2085.0	2199.4	12.865	2.261	0.266	10.365	10.631	0.975

Legends: GlobHor : Horizontal global irradiation  
 GlobEff : Effective Global, corr. for IAM and shadings  
 E Avail : Available Solar Energy  
 E Unused : Unused energy (full battery) loss


E Miss : Missing energy  
 E User : Energy supplied to the user  
 E Load : Energy need of the user (Load)  
 SolFrac : Solar fraction (EUsed / ELoad)

### Stand Alone System: Loss diagram

**Project :** Stand Alone Project at Mehaires  
**Simulation variant :** Case 3 august 02 consumptions  
 Simulation for the first year of operation

Main system parameters	System type	Stand alone		
PV Field Orientation	tilt	25°	azimuth	0°
PV modules	Model	REC 300PE 72	Pnom	300 Wp
PV Array	Nb. of modules	24	Pnom total	7.20 kWp
Battery	Model	Solar 12V / 160 Ah	Technology	sealed, Gel
battery Pack	Nb. of units	12	Voltage / Capacity	48 V / 480 Ah
User's needs	Daily household consumers	Constant over the year	global	10.63 MWh/year

#### Loss diagram over the whole year



### Stand Alone System: Economic evaluation

**Project :** Stand Alone Project at Mehaires  
**Simulation variant :** Case 3 august 02 consumptions  
 Simulation for the first year of operation

Main system parameters	System type	Stand alone		
PV Field Orientation	tilt	25°	azimuth	0°
PV modules	Model	REC 300PE 72	Pnom	300 Wp
PV Array	Nb. of modules	24	Pnom total	7.20 kWp
Battery	Model	Solar 12V / 160 Ah	Technology	sealed, Gel
battery Pack	Nb. of units	12	Voltage / Capacity	48 V / 480 Ah
User's needs	Daily household consumers	Constant over the year	global	10.63 MWh/year

#### Investment

PV modules (Pnom = 300 Wp)	24 units	202 € / unit	4848 €
Supports / Integration		83 € / module	2000 €
Batteries ( 12 V / 160 Ah)	12 units	174 € / unit	2088 €
regulator			5000 €
Settings, wiring, ...			1000 €
Substitution underworth			0 €
<b>Gross investment (without taxes)</b>			<b>14936 €</b>

#### Financing

Gross investment (without taxes)		14936 €
Taxes on investment (VAT)	Rate 15.0 %	2240 €
Gross investment (including VAT)		17176 €
Subsidies		0 €
<b>Net investment (all taxes included)</b>		<b>17176 €</b>
Annuities	( Loan 5.0 % over 20 years)	1378 €/year
Maintenance		0 €/year
insurance, annual taxes		0 €/year
Provision for battery replacement	(lifetime 6.5 years)	7037 €/year
<b>Total yearly cost</b>		<b>8415 €/year</b>

#### Energy cost

Used solar energy	10.4 MWh / year
Excess energy (battery full)	2.3 MWh / year
Used energy cost	0.81 € / kWh

### Stand Alone System: CO2 Balance


**Project :** Stand Alone Project at Mehaires  
**Simulation variant :** Case 3 august 02 consumptions  
 Simulation for the first year of operation

Main system parameters	System type	Stand alone		
PV Field Orientation	tilt	25°	azimuth	0°
PV modules	Model	REC 300PE 72	Pnom	300 Wp
PV Array	Nb. of modules	24	Pnom total	7.20 kWp
Battery	Model	Solar 12V / 160 Ah	Technology	sealed, Gel
battery Pack	Nb. of units	12	Voltage / Capacity	48 V / 480 Ah
User's needs	Daily household consumers	Constant over the year	global	10.63 MWh/year

<b>Produced Emissions</b>	Total:	7.60 tCO2	
	Source:	Detailed calculation from table below	
<b>Replaced Emissions</b>	Total:	206.1 tCO2	
	System production:	12.87 MWh/yr	Lifetime: 30 years
			Annual Degradation: 1.0 %
	Grid Lifecycle Emissions:	534 gCO2/kWh	
	Source:	IEA List	Country: World
<b>CO2 Emission Balance</b>	Total:	171.2 tCO2	

#### System Lifecycle Emissions Details:

Item	Modules	Supports
LCE	343 kgCO2/kWp	4.40 kgCO2/kg
Quantity	15.0 kWp	560 kg
Subtotal [kgCO2]	5138	2465



CASE 6

PVSYST V6.63		28/08/17	Page 1/6
<b>Stand Alone System: Simulation parameters</b>			
<b>Project :</b>	<b>Stand Alone Project at Mehaires</b>		
<b>Geographical Site</b>	<b>Mehaires</b>		
<b>Situation</b>	Latitude	26.17 °N	Longitude -11.09 °W
Time defined as	Legal Time	Time zone UT	Altitude 375 m
	Albedo	0.20	
<b>Meteo data:</b>	<b>Mehaires</b>	NASA-SSE satellite data, 1983-2005 - Synthetic	
<b>Simulation variant :</b>	<b>Case 6 august 04 consumptions 60V</b>		
	Simulation date	28/08/17 18h24	
	Simulation for the	<b>first year of operation</b>	
<b>Simulation parameters</b>			
<b>Collector Plane Orientation</b>	Tilt	25°	Azimuth 0°
<b>Models used</b>	Transposition	Perez	Diffuse Perez, Meteonorm
<b>PV Array Characteristics</b>			
<b>PV module</b>	Si-poly	Model REC 300PE 72	
Original PVsyst database	Manufacturer REC		
Number of PV modules	In series	2 modules	In parallel 17 strings
Total number of PV modules	Nb. modules	34	Unit Nom. Power 300 Wp
Array global power	Nominal (STC)	10.20 kWp	At operating cond. 9.18 kWp (50°C)
Array operating characteristics (50°C)	U mpp	66 V	I mpp 139 A
Total area	Module area	66.3 m²	Cell area 59.6 m²
<b>PV Array loss factors</b>			
Thermal Loss factor	Uc (const)	20.0 W/m²K	Uv (wind) 0.0 W/m²K / m/s
Wiring Ohmic Loss	Global array res.	7.8 mOhm	Loss Fraction 1.5 % at STC
Serie Diode Loss	Voltage Drop	0.7 V	Loss Fraction 1.0 % at STC
LID - Light Induced Degradation			Loss Fraction 1.5 %
Module Quality Loss			Loss Fraction -0.4 %
Module Mismatch Losses			Loss Fraction 1.0 % at MPP
Module average degradation	Year no	1	Loss factor 0.4 %/year
Mismatch due to degradation	Imp dispersion RMS	0.4 %/year	Voc dispersion RMS 0.4 %/year
Incidence effect, ASHRAE parametrization	IAM =	1 - bo (1/cos i - 1)	bo Param. 0.05
<b>System Parameter</b>	System type	<b>Stand Alone System</b>	
<b>Battery</b>	Model Solar 12V / 160 Ah		
	Manufacturer Generic		
<b>Battery Pack Characteristics</b>	Voltage 60 V	Nominal Capacity 480 Ah	
	Nb. of units 5 in series x 3 in parallel		
	Temperature External ambient temperature		
<b>Controller</b>	Model Universal controller with MPPT converter		
	Technology MPPT converter	Temp coeff. -5.0 mV/°C/elec.	
<b>Converter</b>	Maxi and EURO efficiencies 97.0/95.0 %		
<b>Battery management control</b>	Threshold commands as SOC calculation		
	Charging SOC = 0.90 / 0.75	i.e. approx. 67.6 / 61.9 V	
	Discharging SOC = 0.20 / 0.45	i.e. approx. 58.0 / 60.3 V	
<b>User's needs :</b>	Daily household consumers average	Constant over the year 41 kWh/Day	

### Stand Alone System: Detailed User's needs


**Project :** Stand Alone Project at Mehaires  
**Simulation variant :** Case 6 august 04 consumptions 60V  
 Simulation for the first year of operation

Main system parameters	System type	Stand alone		
PV Field Orientation	tilt	25°	azimuth	0°
PV modules	Model	REC 300PE 72	Pnom	300 Wp
PV Array	Nb. of modules	34	Pnom total	10.20 kWp
Battery	Model	Solar 12V / 160 Ah	Technology	sealed, Gel
battery Pack	Nb. of units	15	Voltage / Capacity	60 V / 480 Ah
User's needs	Daily household consumers	Constant over the year	global	15.07 MWh/year

Daily household consumers, Constant over the year, average = 41 kWh/day

**Annual values**

	Number	Power	Use	Energy
Lamps (LED or fluo)	1	50 W/lamp	8 h/day	400 Wh/day
TV / PC / Mobile	1	200 W/app	5 h/day	1000 Wh/day
Domestic appliances	1	1000 W/app	6 h/day	6000 Wh/day
Fridge / Deep-freeze	1		24 Wh/day	3600 Wh/day
Dish- & Cloth-washers	1		1 Wh/day	1000 Wh/day
Other uses	1	4797 W tot	6 h/day	28782 Wh/day
Other uses	1	1000 W tot	1 h/day	500 Wh/day
Total daily energy				41282 Wh/day




### Stand Alone System: Main results

**Project :** Stand Alone Project at Mehaires  
**Simulation variant :** Case 6 august 04 consumptions 60V  
 Simulation for the first year of operation

Main system parameters	System type	Stand alone		
PV Field Orientation	tilt	25°	azimuth	0°
PV modules	Model	REC 300PE 72	Pnom	300 Wp
PV Array	Nb. of modules	34	Pnom total	10.20 kWp
Battery	Model	Solar 12V / 160 Ah	Technology	sealed, Gel
battery Pack	Nb. of units	15	Voltage / Capacity	60 V / 480 Ah
User's needs	Daily household consumers	Constant over the year	global	15.07 MWh/year

Main simulation results	Available Energy	Specific prod.	17.91 MWh/year
System Production	Used Energy	Excess (unused)	14.70 MWh/year
	Performance Ratio PR	Solar Fraction SF	63.72 %
Loss of Load	Time Fraction	Missing Energy	2.94 MWh/year
Investment	Global incl. taxes	Specific	0.37 MWh/year
Yearly cost	Annuities (Loan 5.0%, 20 years)	Running Costs	2.06 €/Wp
Energy cost			7037 €/yr
			0.59 €/kWh



Case 6 august 04 consumptions 60V  
 Balances and main results

	GlobHor kWh/m <sup>2</sup>	GlobEff kWh/m <sup>2</sup>	E Avail MWh	E Unused MWh	E Miss MWh	E User MWh	E Load MWh	SolFrac
January	118.1	160.4	1.360	0.104	0.041	1.239	1.280	0.968
February	151.3	162.2	1.353	0.188	0.015	1.141	1.156	0.987
March	182.6	203.2	1.672	0.370	0.000	1.280	1.280	1.000
April	209.4	206.8	1.687	0.417	0.000	1.238	1.238	1.000
May	229.1	206.1	1.679	0.376	0.000	1.280	1.280	1.000
June	226.8	196.1	1.587	0.319	0.000	1.238	1.238	1.000
July	227.8	202.0	1.603	0.297	0.000	1.280	1.280	1.000
August	210.8	201.6	1.593	0.294	0.000	1.280	1.280	1.000
September	176.1	186.5	1.483	0.240	0.000	1.238	1.238	1.000
October	149.7	177.1	1.424	0.173	0.062	1.218	1.280	0.952
November	118.5	154.5	1.267	0.096	0.090	1.148	1.238	0.927
December	104.8	143.0	1.198	0.068	0.161	1.118	1.280	0.874
Year	2085.0	2199.4	17.906	2.944	0.369	14.699	15.068	0.976

Legends: GlobHor = Horizontal global irradiation  
 GlobEff = Effective Global, corr. for IAM and shadings  
 E Avail = Available Solar Energy  
 E Unused = Unused energy (full battery) loss


E Miss = Missing energy  
 E User = Energy supplied to the user  
 E Load = Energy need of the user (Load)  
 SolFrac = Solar fraction (EUsed / ELoad)

### Stand Alone System: Loss diagram

**Project :** Stand Alone Project at Mehaires  
**Simulation variant :** Case 6 august 04 consumptions 60V  
 Simulation for the first year of operation

Main system parameters	System type	Stand alone		
PV Field Orientation	tilt	25°	azimuth	0°
PV modules	Model	REC 300PE 72	Pnom	300 Wp
PV Array	Nb. of modules	34	Pnom total	10.20 kWp
Battery	Model	Solar 12V / 160 Ah	Technology	sealed, Gel
battery Pack	Nb. of units	15	Voltage / Capacity	60 V / 480 Ah
User's needs	Daily household consumers	Constant over the year	global	15.07 MWh/year

#### Loss diagram over the whole year



### Stand Alone System: Economic evaluation

**Project :** Stand Alone Project at Mehaires  
**Simulation variant :** Case 6 august 04 consumptions 60V  
 Simulation for the first year of operation

Main system parameters	System type	Stand alone		
PV Field Orientation	tilt	25°	azimuth	0°
PV modules	Model	REC 300PE 72	Pnom	300 Wp
PV Array	Nb. of modules	34	Pnom total	10.20 kWp
Battery	Model	Solar 12V / 160 Ah	Technology	sealed, Gel
battery Pack	Nb. of units	15	Voltage / Capacity	60 V / 480 Ah
User's needs	Daily household consumers	Constant over the year	global	15.07 MWh/year

#### Investment

PV modules (Pnom = 300 Wp)	34 units	202 € / unit	6868 €
Supports / Integration		83 € / module	2833 €
Batteries ( 12 V / 160 Ah)	15 units	174 € / unit	2610 €
regulator			5000 €
Settings, wiring, ...			1000 €
Substitution underworth			0 €
<b>Gross investment (without taxes)</b>			<b>18311 €</b>

#### Financing

Gross investment (without taxes)		18311 €
Taxes on investment (VAT)	Rate 15.0 %	2747 €
Gross investment (including VAT)		21058 €
Subsidies		0 €
<b>Net investment (all taxes included)</b>		<b>21058 €</b>
Annuities	( Loan 5.0 % over 20 years)	1690 €/year
Maintenance		0 €/year
insurance, annual taxes		0 €/year
Provision for battery replacement	(lifetime 6.8 years)	7037 €/year
<b>Total yearly cost</b>		<b>8727 €/year</b>

#### Energy cost

Used solar energy	14.7 MWh / year
Excess energy (battery full)	2.9 MWh / year
Used energy cost	0.59 € / kWh

### Stand Alone System: CO2 Balance


**Project :** Stand Alone Project at Mehaires  
**Simulation variant :** Case 6 august 04 consumptions 60V  
 Simulation for the first year of operation

Main system parameters	System type	Stand alone		
PV Field Orientation	tilt	25°	azimuth	0°
PV modules	Model	REC 300PE 72	Pnom	300 Wp
PV Array	Nb. of modules	34	Pnom total	10.20 kWp
Battery	Model	Solar 12V / 160 Ah	Technology	sealed, Gel
battery Pack	Nb. of units	15	Voltage / Capacity	60 V / 480 Ah
User's needs	Daily household consumers	Constant over the year	global	15.07 MWh/year

<b>Produced Emissions</b>	Total:	7.60 tCO2	
	Source:	Detailed calculation from table below	
<b>Replaced Emissions</b>	Total:	286.9 tCO2	
	System production:	17.91 MWh/yr	Lifetime: 30 years
			Annual Degradation: 1.0 %
	Grid Lifecycle Emissions:	534 gCO2/kWh	
	Source:	IEA List	Country: World
<b>CO2 Emission Balance</b>	Total:	241.3 tCO2	

#### System Lifecycle Emissions Details:

Item	Modules	Supports
LCE	343 kgCO2/kWp	4.40 kgCO2/kg
Quantity	15.0 kWp	560 kg
Subtotal [kgCO2]	5138	2465



## APPENDIX G: PUMP CALCULATIONS

### Cases 0-4

$$Power [W] = Q[m^3/s] \times \rho[kg/m^3] \times g[m/s^2] \times H[m] \quad (1)$$

$$Q = \frac{7 m^3/day}{5 h/day} = 1.4 \frac{m^3}{h} = 1.4 \frac{m^3}{h} \times \frac{1 h}{3600 s} = 0.000389 m^3/s$$

$$Power (hydraulic) = 0.000389 \frac{m^3}{s} \times 1007 \frac{kg}{m^3} \times 9.81 \frac{m}{s^2} \times 100m = 384.28 W = 0.384 kW$$

$$Power (required) = \frac{0.384 kW}{0.75} = 0.512 kW$$

$$Energy \left[ \frac{kWh}{day} \right] = Power [kW] \times t \left[ \frac{h}{day} \right]$$

$$Energy = 0.512 kW \times 5 \frac{h}{day} = 2.56 kWh/day$$

$$Energy required for pumping [kWh/day] = \frac{Q[m^3/day] \times \rho[kg/m^3] \times g[m/s^2] \times H[m]}{\eta \times 3600[s/h] \times 1000[W/kW]} \quad (2)$$

$$Energy required for pumping \left[ \frac{kWh}{day} \right] = \frac{7 \frac{m^3}{day} \times 1007 \frac{kg}{m^3} \times 9.81 \frac{m}{s^2} \times 100 m}{0.75 \times 3600 \frac{s}{h} \times 1000 \frac{W}{kW}} = 2.56 kWh/day$$

### Case 5-7

$$Power [W] = Q[m^3/s] \times \rho[kg/m^3] \times g[m/s^2] \times H[m] \quad (1)$$

$$Q = \frac{12.8 m^3/day}{5 h/day} = 2.56 \frac{m^3}{h} = 2.56 \frac{m^3}{h} \times \frac{1 h}{3600 s} = 0.000711 m^3/s$$

$$Power (hydraulic) = 0.000711 \frac{m^3}{s} \times 1007 \frac{kg}{m^3} \times 9.81 \frac{m}{s^2} \times 100m = 702.48 W = 0.70248 kW$$

$$Power (required) = \frac{0.70248 kW}{0.75} = 0.9366 kW$$

$$Energy \left[ \frac{kWh}{day} \right] = Power [kW] \times t \left[ \frac{h}{day} \right]$$

$$Energy = 0.9366 kW \times 5 \frac{h}{day} = 4.68 kWh/day$$

$$Energy required for pumping [kWh/day] = \frac{Q[m^3/day] \times \rho[kg/m^3] \times g[m/s^2] \times H[m]}{\eta \times 3600[s/h] \times 1000[W/kW]} \quad (2)$$

$$Energy required for pumping \left[ \frac{kWh}{day} \right] = \frac{12.8 \frac{m^3}{day} \times 1007 \frac{kg}{m^3} \times 9.81 \frac{m}{s^2} \times 100 m}{0.75 \times 3600 \frac{s}{h} \times 1000 \frac{W}{kW}} = 4.68 kWh/day$$

## APPENDIX H: DIAGRAM OF THE SYSTEM

